



150008220691

# 防爆电气设备 Explosion-proof electrical apparatus



# 防爆合格证

## Conformity certificate of Explosion-proof

证书编号 SYEx18. 0978X  
Certificate No.

制造商 Manufacturer	昆山蓝江电气科技有限公司	
地址 Address	巴城镇学院路 88 号 1 幢 3 层	
生产企业 Factory	安徽蓝盛电气股份有限公司	
地址 Address	芜湖市鸠江区电子产业园综合楼 10 楼 1037 室	
产品名称 Name of product	防爆尼龙电缆接头	
型号规格 Type specification	LAND-PA	
防爆标志 Ex-marking	Ex e II C Gb/Ex tD A20 IP66	
产品标准 Product standards	Q/LAND-003-2018	图样编号 Drawing No. LAND-PA. 1~12
备注 Note	1. 产品安装后应符合防爆型式要求。 2. 可代表螺纹规格：(M12、M16、M18、M20、M22、M24、M25、M27、M30、M32、M36、M40、M50、M63、M75) × 1.5、M90 × 2、M115 × 2、NPT1/4~NPT4、G1/4~G4。	



经对上述产品图样及技术文件的审查和样品检验，确认符合下列标准：

According to the above examination of product designs drawings and technical documents, and sample inspection, it has been confirmed that the following standards are met:

GB 12476. 1-2013	可燃性粉尘环境用电气设备 第 1 部分：通用要求
GB 12476. 5-2013	可燃性粉尘环境用电气设备 第 5 部分：外壳保护型“tD”
GB 3836. 1-2010	爆炸性环境 第 1 部分：设备 通用要求
GB 3836. 3-2010	爆炸性环境 第 3 部分：由增安型“e”保护的的设备

批准  
Approved by

发证日期  
Date of issue

2018-11-07

证书有效期至  
Valid date

2023-11-06



机械工业低压防爆电器产品质量监督检测中心  
Machinery industry Product Quality Supervisory and Test  
Center of Low-voltage Explosion-proof Electrical Product



地址 Address: 沈阳市于洪区巢湖街 10 号  
电话 Tel: 024-25833213、25833649-8033、8037  
证书查询网址 Query URL: www.fbdqhy.com

邮编 Postcode: 110141  
传真 Fax: 024-25303261-8037  
E-mail: sy\_ex@sina.com

注：本证书仅对与审查认可文件及检验样品一致的产品有效。Note: This certificate is valid only for products which are in agreement with the review and approval documents and samples.